

**Longwood University Fire Alarm Systems**  
**(In Order By Building)**

**At this Time all Residence Halls Report Fire Alarms Using the Lenel System**

ARC - Complete System, Smoke Detectors in each room, Heat sensors in certain areas, And Emergency Lighting, and the panel is located in the **electrical closet across From the Trash room**; *Model FAST IRC-3 (Fire Alarm System Tech)*

Barlow- Smoke Detectors and Pull Stations. **Panel is located just inside Registration Office.** *Cerberus Pyrotronics System 3 CP-35*

Blackwell - 110 volt Pull Stations

Bedford- 110 volt Pull Stations

Cox- **Panel is located inside the main lobby door on the first floor hallway.** Pull Stations and smokes are connected to the system in the halls of every floor. The Rooms are on local A/C Smokes; *Cerberus Pyrotronics MXL-IQ*

Craft House – Battery Operated Smoke detectors

Cunningham (Main, North, and South) - Pull Stations in hallways, Local Smoke In each Room, Old Panel box next to new one (needs to be removed) Both are located in the **Housekeeping closet on first main**, Only Battery Powered Smoke Detectors in large suite at the Jeffers side and The TKE Chapter room. *Model Pyrotronics System 3*

Curry and Frazier - All floors have Smoke detectors in the halls and pull stations, Individual rooms have local smoke detectors. **The panels are located in the electrical closet next to roll up door at the mechanical room** *FCI 7100 series*

Curry/Frazier Commons- Smoke Detectors and Pull Stations. **Panel Located in Housekeeping Closet in the center of the Commons.** *FCI 7100 Series*

New Dining Hall - Complete System, Smoke and Heat Sensors Through out, Pull Stations, gas detection system in kitchen, and Reports using a dialer.

Panel is located in electrical closet on the ground floor near the Loading dock; *FCI 7200*

French - **Panel is located in the main lobby and also first floor housekeeping closet.** First floor is a complete system including rooms, second and third floor have Pulls and smokes in common areas, but the rooms have battery powered Detectors; *2 Cerberus Pyrotronics MXL-IQ*

Golf Course – Fire/Bugler Alarm system (Vector Security Monitors) One Battery Powered smoke detector

Hiner - **Panel is located in the electrical closet in the Hiner/Conyer connector On the ground floor.** Information panel located on the first floor connector. Complete system with full building coverage. *Cerberus Pyrotronics MXL-IQ Coyner (Simplex 1970 type 4246-1, serial # A56296)*

Hull - Full building system, **Panel located in Mechanical room on the Ground floor Inside the electrical closet;** *Simplex 4002*

Jarman - Local System, Just Pull Stations throughout the building; *Simplex*

Lancaster - Full building system, **Panel Located in Main lobby off High St. In the closet to the left of the receptionist desk.** *Cerberus Pyrotronics IXL*

Lancer - Pull stations thru out, and some smoke detectors, local building alarm only. **Panel is located in Electrical closet just inside pool locker room entrance.** *Gamewell Flexalarm III*

Lankford- 110 volt Pull Station

Library - Full building system, reports on a dialer, **Panel is located just in side the Checkout desk.** *Simplex 4100*

South Ruffner - Full Building system, **Panel is located just inside the main door** *2 Cerberus Pyrotronics MXL-IQ*

South Tabb - Pull stations and Smoke detectors in the hall ways, Local alarms in rooms **Panel is located in Colonnades front desk office;** *Cerberus Pyrotronics MXL-IQ*

Stevens- 110 volt Pull Stations

Stubbs- Pull stations and Smoke detectors in the hall ways, Local alarms in rooms **Panel is located next the front desk in the lobby before entering the inside Card door;** *Cerberus Pyrotronics MXL-IQ*

Tabb- Full building system, **Panel is located in Sprinkler closet on West side of first Floor;** *2 Cerberus Pyrotronics MXL-IQ*

Wheeler- Pull stations and Smoke detectors in the hall ways, Local alarms in rooms  
**Panel is located next the front desk in the lobby before entering the inside Card door;** *Cerberus Pyrotronics MXL-IQ*

Wygala- 110 volt Pull Stations

Wynne- Pull Stations and Smoke detectors, **Panel is located in electrical room on Playground side.** *Cerberus Pyrotronics SXL-EX*